Theodore G. Bayer & Son, Inc
1167 North Washington St.
Wilkes Barre PA 18705-1856
570-825-2699

Email completed form to: bayer@valleywoodcraft.com

Cable Supports Order Form

COPPER THHN SIMPULL

Customer:
DATE: 10/28/2022

Part No.	Conduit Size	Description
CW15-1	1-1/2"	1-1/2" up to 1-4 cables
CW15-2	1-1/2"	1-1/2" 5 or more
CW20-1	2"	2" up to 1-4 cables
CW20-2	2"	2" 5 or more
CW25-1	2-1/2"	2-1/2" up to 1-4 cables
CW25-2	2-1/2"	2-1/2" 5 or more
CW30-1	3"	3" - up to 1-4 cables
CW30-2	3"	3" - 5 or more
CW35-1	3-1/2"	3-1/2" up to 1-4 cables
CW35-2	3-1/2"	3-1/2" 5 or more
CW40-1	4"	4" - up to 1-4 cables
CW40-2	4"	4" - 5 or more

Due to limited configurations with conduit and conductor sizes, all prices are subject to change pending final review by engineering.

Letter	Cable Size	Cable OD" in
A	#14	0.109
B	#12	0.128
C	#10	0.161
D	#8	0.213
E	#6	0.249
F	#4	0.318
G	#3	0.346
H	#2	0.378
I	#1	0.435
J	1/0	0.474

Letter	Cable Size	Cable OD" in
K	2/0.	0.518
L	3/0.	0.568
M	4/0.	0.624
N	250	0.694
O	300	0.77
P	350	0.797
Q	400	0.842
R	500	0.926
S	600	1.024
T	750	1.126

Special Fire Alarm		
Letter	Cable Size	Cable OD" in
X	14/2	0.236
Z	16/2	0.215

Part No.	*Cable 1*	*Cable 2*	*Cable 3*	*Cable 4*	*Cable 5*	*Cable 6*	*Cable 7*	*Cable 8*	*Pull-Box Designation*	*Total*	*FLOOR*